

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3225-1581:100

Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: Acme Engineering & Mfg. Corp., P.O. Box 978, Muskogee, OK 77402
Contact: Michael Almaguer (918) 684-0523

DESIGN: Models FD-4, FD-12, FD-4SS, FD12SS and FD-2 and FD-4-3, FD-12-3. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, fire rating and UL label.

APPROVAL: Models FD-4, FD-12 FD-4SS, FD-12SS and FD-2 are approved as 1-1/2 hour fire rated fire dampers. Models FD-4-3 and FD-12-3 are approved as 3-hour fire rated fire dampers.

NOTE: Leakage rating not evaluated. Refer to CSFM Listing Category 3230 for leakage rated dampers.

XLF: 3225-0368:101

11-04-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 6, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager